

## 2005 ANNUAL ANALYSIS OF CEDAR & TOLT WATER SUPPLIES

Distribution Water Quality *(unless otherwise noted)*  
 Samples Collected: May 10, 2005 *(unless otherwise noted)*

Tolt Distribution = Higher elevations North of the ship canal.

Cedar Distribution = South of the ship canal & lower elevations North of ship canal.

Water Quality Parameter	State Dept. of Health Maximum Contaminant Level	CEDAR	TOLT	Minimum Reporting Level
Primary Standards *	MCL			
Antimony	6 ug/L	ND	ND	1.0
Arsenic	50 ug/L	ND	ND	1.0
Asbestos \$	7 million fibers/L (>10um long)	ND	ND	0.2
Barium	2000 ug/L	1.9	2.4	1.0
Beryllium	4 ug/L	ND	ND	0.2
Bromate #	10 ug/L	ND (5/04/05)	ND (5/11/05)	5.0
Cadmium	5 ug/L	ND	ND	0.2
Chromium	100 ug/L	ND	ND	1.0
Cyanide	200 ug/L	ND	ND	10
Fluoride	4 mg/L	0.95	1.02	0.10
Haloacetic Acids(5), Total ~	60 ug/L	21.7	29.4	1.0
Mercury	2 ug/L	ND	ND	0.1
Nickel	100 ug/L	ND	ND	1.0
Nitrate-Nitrogen	10 mg/L	0.055	0.15	0.01
Nitrite-Nitrogen	1 mg/L	ND	ND	0.002
Selenium	50 ug/L	ND	ND	1.0
Thallium	2 ug/L	ND	ND	0.2
Trihalomethanes, Total~	80 ug/L	31.4	46.2	0.5
Turbidity #	5 NTU for Cedar/ 0.30 NTU for Tolt	0.38	0.13	0.05
Secondary Standards **	SMCL			
Aluminum	50 - 200 ug/L	16	38	1.0
Chloride	250 mg/L	4.7	3.3	0.5
Color	15 std. units	ND	ND	5.0
Copper	1000 ug/L	1.4	ND	1.0
Fluoride	2 mg/L	0.95	1.02	0.10
Iron	0.3 mg/L	0.036	0.014	0.004
Manganese	50 ug/L	2.6	ND	1.0
pH, range ++	6.5 - 8.5 pH units	7.95 - 8.52	8.00 - 8.34	NA
Silver	100 ug/L	ND	ND	1.0
Solids, Total Dissolved	500 mg/L	47.5	38.7	5.0
Specific Conductance	700 umhos/cm	76.0	71.0	5.0
Sulfate	250 mg/L	ND	1.4	1.0
Zinc	5000 ug/L	1.5	ND	1.0
Other Parameters	Units			
Alkalinity, Total (as CaCO3)	mg/L	21.3	19.7	2.0
Bromide	ug/L	ND	ND	5
Calcium, (as CaCO3)	mg/L	25.2	27.5	2.0
Hardness, (as CaCO3)	mg/L	29.8	29.0	2.0
Hardness, (as CaCO3)	grains/gal.	1.72	1.68	0.1
Magnesium	mg/L	1.11	0.37	0.01
Oxygen, Dissolved	mg/L	12.5	16.2	0.5
Phosphate, soluble-reactive	ug/L	1	2	1
Potassium	mg/L	0.27	0.13	0.02
Silica, Reactive	mg/L	8.20	5.50	1.0
Sodium	mg/L	2.76	1.72	0.08
Temperature, normal annual range	deg. C.	5 - 20	5 - 20	NA
Total Organic Carbon #	mg/L	0.84	1.06	0.20
Lead, Source water	ug/L	ND	ND	1.0
Residential Survey @	Action Level	Combined System		
2004 Lead	15 ug/L	10.4		1.0
2005 Lead		7.0		
2004 Copper	1300 ug/L	264		1.0
2005 Copper		156		

*Primary and Secondary Standards were measured at the Intake to the distribution system after treatment.*

\* Health stds.: Supplier subject to public notification.

++ January-June 2005, 10-90th percentile

\*\* Aesthetic stds.: Supplier not subject to public notification.

\$ Test results 12/15/95 - To be analyzed by 2007.

~ Average of the last 4 quarters testing, through 5/05.

# As measured at treatment plant.

ND = Not Detected at or above the Minimum Reporting Level

1 ppm = 1 mg/L = 1000 ug/L

@ Measured at 90th percentile of overnight standing residential samples from homes with copper pipes and lead solder.

Seattle Public Utilities Water Quality Laboratory, 800 S. Stacy St., Seattle 98134 (206) 684-7834

<http://www.seattle.gov/util/services/waterquality/>