


DETAIL A

7" ± DIA. SS BAND CLAMP
REQUIRED OVER 70%
SEE NOTE 5

NOTES:

1. NO BENDS (VERTICAL OR HORIZONTAL ALLOWED IN R/W OR EASEMENT WITHOUT SPECIAL PERMISSION FROM THE DISTRICT.
2. SIDE SEWERS SHALL BE BEDDED WITH A MIN. OF 6" OF PEA GRAVEL OR 5/8" MINUS CRUSHED ROCK UNDER AND OVER THE PIPE.
3. SIDE SEWERS SHALL BE 6" DIA. AND THE SAME MATERIAL AS THE MAINLINE. DUCTILE IRON SIDE SEWERS MAY TRANSITION TO PVC AT THE R/W OR ESM'T LINE WITH APPROVED COUPLING OR TRANSITION GASKET.
4. INSTALL A MIN. 8' TAIL PIECE (6" PVC) TO PREVENT FUTURE UNDERMINING OF CLEANOUT AND SIDEWALK. USE A ROMAC 501 COUPLING OR TRANSITION GASKET WITH FOLLOWER TO TRANSITION FROM DUCTILE IRON AFTER CLEANOUT WYE.
5. CLEANOUT PER STD PLAN 14 SHALL BE INSTALLED AT THE R/W OR ESM'T LINE AND BEHIND THE SIDEWALK. IF BACK OF SIDEWALK IS AT R/W A 5'x5' EASEMENT SHALL BE REQUIRED.
6. STAINLESS STEEL BAND CLAMPS REINFORCEMENT REQUIRED ON PVC SIDE SEWER TEES WHERE SLOPE IS GREATER THAN 70% (.7' RISE PER FOOT) SEE DETAIL A.
7. GASKETED PVC CAP SHALL BE USED AT THE END OF THE STUB. CHERNE TYPE PLUGS ARE NOT ALLOWED TO BE BURIED.
8. CLEANOUT STANDPIPE PIPE SIZE SHALL MATCH THE SIZE AND MATERIAL OF THE SIDE SEWER.



**Woodinville
Water District**

**STANDARD SIDE SEWER
INSTALLATION**



**SEWER STD.
PLAN NO. 15**

REVISION DATE
04/25