



NOTES:

1. CONTRACTOR SHALL LOCATE DIA. X 6" TEE AT HIGH POINT IN THE MAIN. THE MAINLINE GENERALLY NEEDS TO BE DEEPER THAN 3' TO PROVIDE BURY DEPTH AT THE AIR RELEASE BOX AND 2" GALV. DISCHARGE PIPING. SEE SPECIFICATIONS FOR ADDITIONAL REQUIREMENTS.
2. SEE STANDARD PLAN 6 FOR VALVE BOX REQUIREMENTS.
3. METAL LID TO HAVE A PICK HOLE OR PICK NOTCH. METER FLAP NOT ALLOWED.
4. AIR VAC PIPING TO BE PAINTED (2) COATS OF SAFETY YELLOW. VALVE & AIR VAC BOX LIDS TO BE PAINTED (2) COATS OF SAFETY BLUE. SEE MW-24 FOR PAINT SPECIFICATIONS.
5. AIR RELEASE AND PIPING SHALL BE INCLUDED IN PRESSURE TESTING.
6. PLACE VALVE TYPE AND SIZE INDICATOR IN VALVE CHAMBER. **SEE STANDARD PLAN 23.**



Woodinville
Water District

AIR RELEASE
ASSEMBLY



WATER STD.
PLAN NO. 11

REVISION DATE
04/25