


1" SEE STANDARD PLAN 13B FOR MATERIAL LIST

NOTE - CIRCLED NUMBERS ABOVE REFER TO MATERIALS LISTED ON STD PLAN 13B.


NOTES:

1. CONTRACTOR TO PROVIDE ALL MATERIALS AS SHOWN EXCEPT METERS.
2. TRACE WIRES MUST BE VISIBLE IN METER BOX.
3. NO SPLICES ALLOWED IN SERVICE LINES.
4. CONTRACTOR SHALL SCHEDULE SERVICE FLUSH WITH THE DISTRICT INSPECTOR. TAPPING COUPON TO BE PRESENTED TO THE DISTRICT INSPECTOR. SERVICES TO BE TESTED UNDER MAINLINE PRESSURE.
5. EXISTING SERVICE SHALL BE MAINTAINED UNTIL THE NEW SYSTEM IS PRESSURE TESTED, FLUSH AND SATISFACTORY BACTERIOLOGICAL TEST RECEIVED. THEN THE CONTRACTOR SHALL COORDINATE WITH THE INDIVIDUAL OWNER AND THE DISTRICT TO SCHEDULE CONNECTION TO THE NEW SYSTEM. SEE SPECIFICATIONS FOR ADDITIONAL REQUIREMENTS.
6. METER BOX SHALL BE PERPENDICULAR TO SIDEWALK, PROPERTY LINE OR AS DIRECTED. METERS SHALL BE CENTERED IN THE METER BOX AND PARALLEL. BOTH ANGLE METER STOPS SHALL BE VERTICAL AND ACCESSIBLE FOR SHUT OFF WITH A METER KEY. METER BOX NOT ALLOWED IN SIDEWALK. PRIOR APPROVAL REQUIRED FOR INSTALLATIONS IN TRAFFIC AREAS.
7. BACKSIDE CONNECTIONS SHALL BE MADE WITH 1" TYPE 'K' COPPER. FOR LARGER SINGLE FAMILY METERS, SIZE THE BACKSIDE TYPE 'K' COPPER TO THE SIZE OF THE METER. "NO LEAD" BRASS FITTINGS AND CONNECTORS SHALL BE USED FOR RECONNECTION. CONTRACTOR TO PROVIDE ALL MATERIALS.
8. EXISTING METERS TO BE REUSED EXCEPT THOSE IDENTIFIED BY THE DISTRICT TO BE REPLACED. NEW METERS WILL BE SUPPLIED BY THE DISTRICT AND INSTALLED BY THE CONTRACTOR. BACKFILL INSIDE METER BOX TO BOTTOM OF METER REGISTER PER STANDARD PLAN 13B NOTE 8. AMR COMPONENTS SHALL BE TRANSFERRED. CONTRACTOR SHALL REQUEST INSTRUCTION IF UNFAMILIAR WITH OUR AMR COMPONENTS.
9. CONTRACTOR SHALL VERIFY NO INDIVIDUAL PRV EXISTS BETWEEN EXISTING AND NEW CONNECTION POINTS. PRESSURE SHALL MATCH THE PRIOR PRESSURE. IF DIFFERENT, ADDITIONAL STEPS MUST BE TAKEN.
11. METER BOXES INSTALLED ON SLOPES MAY REQUIRE A LANDSCAPE BLOCK WALL TO ACHIEVE A CLEAR AND LEVEL AREA.
12. ALL APPLICABLE DETAILS FROM WATER STANDARD PLAN 13 APPLY TO SINGLE FAMILY SERVICE RECONNECTION.



**Woodinville
Water District**

**SINGLE FAMILY
SERVICE RECONNECTION**



**WATER STD.
PLAN NO. 13A**

REVISION DATE
04/25