


NOTES:

1. THIS STANDARD PLAN IS APPLICABLE FOR NEW OR UPDATED CONSTRUCTION THAT IS NOT PART OF A DEVELOPERS EXTENSION.
2. ALL NOTES FROM WATER STANDARD PLANS 19 AND 19A ARE APPLICABLE TO THIS INSTALLATION.
3. DOMESTIC SERVICE SHALL BE INSTALLED PER STANDARD PLAN 13 (1" SFR RESIDENTIAL SERVICE). METER BOXES SHALL BE PLACED AT THE RIGHT OF WAY LINE OR IN THE UTILITY EASEMENT AS SHOWN.
4. AFTER PROJECT ACCEPTANCE AND METER SET FEES HAVE BEEN PAID, THE METER WILL BE INSTALLED BY THE DISTRICT.
5. IT SHALL BE THE OWNER'S RESPONSIBILITY TO INSURE THAT THE SERVICE LINE AND METER SIZE ARE ADEQUATE TO SERVE THE DOMESTIC WATER SYSTEM REQUIREMENTS.
6. THE BACKFLOW PREVENTION DEVICE SHALL BE A REDUCED PRESSURE BACKFLOW ASSEMBLY AS APPROVED BY THE WASHINGTON STATE DEPARTMENT OF HEALTH OR AS DIRECTED BY THE DISTRICT.
7. PHYSICAL SEPARATION REQUIRED BETWEEN THE AUXILIARY SYSTEM AND THE DISTRICT'S DISTRIBUTION SYSTEM. INSPECTION OF THE PHYSICAL SEPARATION IS REQUIRED PRIOR TO ESTABLISHING WATER SERVICE.
8. INSTALLATION OF THE BACKFLOW PREVENTER CREATES A CLOSED LOOP SYSTEM FOR YOUR PRIVATE WATER SYSTEM. CONSULT WITH THE LOCAL AUTHORITY OR A PLUMBER TO PREVENT ANY THERMAL EXPANSION PROBLEMS.
9. THE BACKFLOW DEVICE SHALL BE INSTALLED BY THE OWNER. INSPECTION REQUIRED ON SERVICE LINE AND BACKFLOW ASSEMBLY INSTALLATION PRIOR TO BACKFILL. CALL 425-487-4100 TO SCHEDULE.
10. INITIAL TEST OF THE RPBA IS REQUIRED TO ESTABLISHMENT OF WATER SERVICE. TEST RESULTS SHALL BE SENT TO WOODINVILLE WATER DISTRICT. ANNUAL TESTING OF THE RPBA BY A CERTIFIED BACKFLOW ASSEMBLY TESTER IS REQUIRED BY THE OWNER. TEST RESULTS SHALL BE SUBMITTED TO THE WOODINVILLE WATER DISTRICT.



Woodinville
Water District

SINGLE FAMILY RESIDENCE W/
AUXILIARY WATER SUPPLY



WATER STD.
PLAN NO. 15

REVISION DATE
04/25