



NOTES:

1. ALL NOTES FROM WATER STANDARD PLAN 19 AND 19A APPLY TO THIS DETAIL.
2. RPBA/RPDA MUST CONNECT IMMEDIATELY ADJACENT TO WATER METER.
3. 120V ELECTRICAL GFCI OUTLET FOR HEAT TAPE REQUIRED. INSTALL AWAY FROM RPBA/RPDA DISCHARGE. INSTALL HEAT TAPE FOR FREEZE PROTECTION.
4. ALL FITTINGS AND BRASS COMPONENTS SHALL CONFORM TO THE LATEST VERSION OF NSF 61 AND ANSI/AWWA STANDARD C800 AND SHALL BE STAMPED/EMBOSSED TO SHOW THE PRODUCT IS MADE FROM A NO LEAD ALLOY.



Woodinville
Water District

2" AND SMALLER DUAL
REDUCED PRESSURE
BACKFLOW ASSEMBLY



WATER STD
PLAN NO. 19B

REVISION DATE
04/25